

1 **EC TYPE EXAMINATION CERTIFICATE**

2 Equipment or protective system intended for use in potentially explosive atmospheres –
Directive 94/9/EC – Annex III

3 EC Type Examination **TRAC12ATEX0030X**
Certificate No.:

4 Equipment: **Ultrasonic Transducers,
i-Series Intelligent Sensors**

5 Manufacturer: **Nivus GmbH,**

6 Address: **Im Täle 2, 75031 Eppingen, Germany**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 TRaC Global Ltd, Notified Body number 0891 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment or protective system intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential report **TRA-008917-33-02A**.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in section 18 of the schedule to this certificate, has been assured by compliance with:

EN60079-0:2009

EN60079-11:2012

EN60079-26:2007

10 If the sign “X” is placed after the certificate number then this indicates that the equipment or protective system is subject to special conditions of safe use specified in the schedule to this certificate.

11 This EC-Type Examination certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of this equipment or protective system shall include the following:

Ex II 1 G Ex ia IIC T4 Ga T_{amb} = -40°C to +80°C

II 1 D Ex ia IIIC T130°C Da

This certificate and its schedules may only be reproduced in its entirety and without change. This certificate is issued in accordance with the TRaC Ex Certification Scheme.

S.P. Winsor

S P Winsor, Certification Officer

Issue date: 2012-09-06

Copy No.: 1e

Page 1 of 5

Form RF355 is16

NORTH WEST

Unit 1, Pendle Place, Skelmersdale, West Lancashire, WN8 9PN UK.

T +44 (0)1695 556666 F +44 (0)1695 557077 E test@tracglobal.com

www.tracglobal.com

13 **SCHEDULE TO EC TYPE EXAMINATION CERTIFICATE**

14 **TRAC12ATEX0030X**

15 **General description of equipment or protective system included within the scope of this certificate**

The “i-Series Intelligent Sensors” are ultrasonic transducers. They are a range of low power, compact acoustic measurement devices and are intended to be powered, via an ATEX approved galvanic / zener barrier or a specialist ATEX approved PSU, by a control unit which also processes the measurement data received.

The range of transducers consists of slightly different constructions with respect to dimensions but all have a non-metallic enclosure which houses 2 internal electronic PCBs and a piezo crystal. The free space internally is potted with 1 of 2 types of material. Each unit has an integral screened cable for the power supply and some of the models use syntactic foam as a facing material.

A list of controlled Manufacturer’s Documents is given in Appendix A to this schedule.

Table of entity parameters	
Parameter	Channel 1
Ui	28V
Ii	162mA
Pi	1.03W
Ci	0
Li	0

16 **Test report No.:** **TRA-008917-33-02A.**

17 **“Special Conditions of Safe Use” for Ex Equipment, if any:**

1. The “i-Series Intelligent Sensors” must be powered by an ATEX approved barrier that meets the following parameters: $U_o = \leq 28V$, $I_o = \leq 162mA$, $P_o = \leq 1.03W$
2. The equipment must be routinely inspected to avoid the build up of dust layers when installed in a Zone 20, 21 & 22.
3. The power supply cable to the transducers shall meet the relevant installation requirements of clause 9 of EN60079-14:2008.

18 **Essential health and safety requirements**

Covered by application of the standards listed in section 9 of this certificate and the assessment conducted in the test report listed in section 16 of this certificate.

19 **Additional information**

“Routine tests”, if any:

None.

“Special conditions for manufacture”, if any:

1. Wiring and potting of the “i-Series Intelligent Sensors” shall be manufactured in accordance with document ref. ‘Special process instruction 9.0, i potting’, rev 1.0, dated 2012-06-13.
2. Conditions for manufacturing and production control are the same as for equipment detailed within report **TRA-008917-33-00A.**

Other information, if any:

None.

Photographs



Details of markings

A-800-0410-A		CE 0044		Gefahr von elektrostatischer Aufladung! Nur mit feuchtem Tuch reinigen! TRAC 12ATEX0030X $U_i=28V$ $I_i=162mA$ $P_i=1.03W$ II 1 G Ex ia IIC T4 Ga $T_{max} = -40^{\circ}C$ to $+80^{\circ}C$ II 1 D Ex ia IIIC T130°C Da
A-800-0411-A		CE 0044		Gefahr von elektrostatischer Aufladung! Nur mit feuchtem Tuch reinigen! TRAC 12ATEX0030X $U_i=28V$ $I_i=162mA$ $P_i=1.03W$ II 1 G Ex ia IIC T4 Ga $T_{max} = -40^{\circ}C$ to $+80^{\circ}C$ II 1 D Ex ia IIIC T130°C Da
A-800-0412-A		CE 0044		Gefahr von elektrostatischer Aufladung! Nur mit feuchtem Tuch reinigen! TRAC 12ATEX0030X $U_i=28V$ $I_i=162mA$ $P_i=1.03W$ II 1 G Ex ia IIC T4 Ga $T_{max} = -40^{\circ}C$ to $+80^{\circ}C$ II 1 D Ex ia IIIC T130°C Da
A-800-0413-A		CE 0044		Gefahr von elektrostatischer Aufladung! Nur mit feuchtem Tuch reinigen! TRAC 12ATEX0030X $U_i=28V$ $I_i=162mA$ $P_i=1.03W$ II 1 G Ex ia IIC T4 Ga $T_{max} = -40^{\circ}C$ to $+80^{\circ}C$ II 1 D Ex ia IIIC T130°C Da

CONTINUATION OF SCHEDULE TO CERTIFICATE TRAC12ATEX0030X

Details of variations to this certificate

- None.

Notes to CE marking

In respect of CE Marking, TRaC Global Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

Notes to this certificate

TRaC certification reference: **TRA-008917-32-00**.

Throughout this certificate, the date format yyyy-mm-dd (year-month-day) is used.



CONTINUATION OF SCHEDULE TO CERTIFICATE TRAC12ATEX0030X

APPENDIX A - LIST OF CONTROLLED MANUFACTURER'S DOCUMENTS

Title:	Drawing No.:	Rev. Level:	Date:
Intelligent Transducer General Layout	D-804-0948-A	A	2011-12-01
HIPA (Hart, imp, PA) Schematic For ATEX Certification	D-804-0949-A	A	2012-01-03
HIPA PCB (3 pages)	D-804-0950-B	B	2012-01-03
ATEX Certified HIPA Ping BOM (2 pages)	*	1.0	2012-01-17
Hart CPU Schematic For ATEX Certification	D-804-0951-A	A	2012-01-03
Hart CPU PCB (4 pages)	D-804-0952-B	B	2012-04-23
ATEX Certified Hart Transducer Processor BOM (3 pages)	*	1.0	2012-01-17
NIVUS i 3, 6, 10 & 15 HART Transducer Wraparound Labels for Ex ia	D-804-0964-C	C	2012-06-27
i Transducer Potting Thickness	D-804-0969-A	A	2012-03-13
i Transducer Block Diagram For Exia	D-804-0979-A	A	2012-04-23
i Transducer Cap	D-804-0980-A	A	2012-04-23
i 3 Standard Housing	D-804-0981-A	A	2012-04-23
i 6 Standard Housing	D-804-0982-A	A	2012-04-23
i 10 Standard Housing	D-804-0983-A	A	2012-04-23
i 15 Standard Housing	D-804-0984-A	A	2012-04-23
i 3 Threaded Nose Housing	D-804-0985-A	A	2012-04-23
i 6 Threaded Nose Housing	D-804-0986-A	A	2012-04-23
i 10 Threaded Nose Housing	D-804-0987-A	A	2012-04-23
i Housing Extension Ring	D-804-0988-A	A	2012-04-23
Special Process Instruction 9.0 i Potting	*	1.0	2012-06-13
Instruction Manual for i-Series Intelligent Sensors	i-Series Sensors	00	2012-07-20

* No information provided.